

Certificate

of Electrical Appliance Testing



Valid Until:
09/06/2017

ASD

**We certify that appliances marked with green pass labels have
been inspected & tested in accordance with the IET Code of
Practice**

Testing carried out by:

Testsafe Ltd
Bretby Business Park
Ashby Road
Burton on Trent
DE15 0YZ
Phone: 01283 229873
Email: sales@test-safe.co.uk

Certificate issued to:

John Curzon
11 Manor Drive
Netherseal
DE12 8DW

PAT Report Passes And Fails For all Sites and Locations

CLIENT DETAILS

Company Name: John Curzon
Address: 11 Manor Drive
Netherseal
DE12 8DW



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING

Company Name: Testsafe Ltd
Address: Bretby Business Park
Ashby Road
Burton on Trent
DE15 0YZ
Telephone: 01283 229873
Fax:
Email: sales@test-safe.co.uk
Cert Number:
Order Number:
File Name: John Curzon_TS12393.PAT
Signature:

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Retest Due	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (KVA)	Leakage (mA)	Overall Status
JOHN CURZON - DISCO EQUIPMENT										
KH612002	8 WAY EXT LEAD	09/06/16	09/06/17	P	P	P 0.05	P >199	S	S	PASS
KH612003	6 WAY SP EXT LEAD	09/06/16	09/06/17	P	P	P 0.12	P >199	S	S	PASS
KH612004	4 WAY EXT LEAD	09/06/16	09/06/17	P	P	P 0.08	P >199	S	S	PASS
KH612005	4 WAY EXT LEAD	09/06/16	09/06/17	P	P	P 0.09	P >199	S	S	PASS
KH612006	IEC LEAD	09/06/16	09/06/17	P	P	P 0.10	P >199	S	S	PASS
KH612007	IEC LEAD	09/06/16	09/06/17	P	P	P 0.08	P >199	S	S	PASS
KH612008	IEC LEAD	09/06/16	09/06/17	P	P	P 0.03	P >199	S	S	PASS
KH612009	IEC LEAD	09/06/16	09/06/17	P	P	P 0.08	P >199	S	S	PASS
KH612010	POWER LEAD	09/06/16	09/06/17	P	P	P 0.12	P >199	S	S	PASS
KH612011	6 WAY EXT LEAD	09/06/16	09/06/17	P	P	P 0.12	P >199	S	S	PASS
KH612012	IEC LEAD	09/06/16	09/06/17	P	P	P 0.10	P >199	S	S	PASS
KH612013	PC BOX	09/06/16	09/06/17	P	S	P 0.16	P >199	S	S	PASS
KH612014	POWER LEAD	09/06/16	09/06/17	P	S	P 0.16	P >199	S	S	PASS
KH612015	IEC LEAD	09/06/16	09/06/17	P	P	P 0.11	P >199	S	S	PASS
KH612016	IEC LEAD	09/06/16	09/06/17	P	P	P 0.12	P >199	S	S	PASS
KH612017	6 WAY EXT LEAD	09/06/16	09/06/17	P	P	P 0.12	P >199	S	S	PASS
KH612018	MALE-FEMALE IEC LEAD	09/06/16	09/06/17	P	P	P 0.10	P >199	S	S	PASS
KH612019	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.13	P >199	S	S	PASS
KH612020	MALE-FEMALE IEC LEAD	09/06/16	09/06/17	P	P	P 0.10	P >199	S	S	PASS
KH612021	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.59	P >199	S	S	PASS
KH612022	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.06	P >199	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Retest Due	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
KH612023	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.06	P >199	S	S	PASS
KH612024	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.03	P >199	S	S	PASS
KH612025	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.03	P >199	S	S	PASS
KH612026	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.03	P >199	S	S	PASS
KH612027	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.03	P >199	S	S	PASS
KH612028	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.03	P >199	S	S	PASS
KH612029	LED UP LIGHTER	09/06/16	09/06/17	P	S	P 0.02	P >199	S	S	PASS
KH612030	SPEAKER	09/06/16	09/06/17	P	S	P 0.05	P >199	S	S	PASS
KH612031	SPEAKER	09/06/16	09/06/17	P	S	P 0.09	P >199	S	S	PASS
KH612032	BASE BIN	09/06/16	09/06/17	P	S	P 0.04	P >199	S	S	PASS
KH612033	BASE BIN	09/06/16	09/06/17	P	S	P 0.05	P >199	S	S	PASS
KH612034	MIXER BOX	09/06/16	09/06/17	P	S	P 0.04	P >199	S	S	PASS
KH612035	TV	09/06/16	09/06/17	P	S	P 0.06	P >199	S	S	PASS
KH612036	25M CABLE REEL INC RCD	09/06/16	09/06/17	P	S	P 0.43	P >199	S	S	PASS
KH612037	SPIN LIGHT	09/06/16	09/06/17	P	S	P 0.03	P >199	S	S	PASS
KH612038	SPIN LIGHT	09/06/16	09/06/17	P	S	P 0.03	P >199	S	S	PASS
KH612039	AC DC ADAPTER	09/06/16	09/06/17	P	S	S	P >199	S	S	PASS
NEEP										

Total Appliances > 38

Total Appliances For Report: 38